

Official Laboratory Report

Report To: NORA KIEFER
1330 BEAMER RD
BLISSFIELD MI 49228

Sample ID: LJ32711
Work Order: 01101072_01

System Name/Owner: BILLAGE OF BLISSFIELD
Collection Address: 1330 BEAMER RD, BLISSFIELD
Collected By: NORA KIEFER
Township/Well#/Section: //
County: Lenawee
Sample Point:
Water System: Treated Public Distribution System

WSSN/Pool ID: 0750
Source: TYPE I
Site Code: TP001
Collector: Other
Date Collected: 11/09/2020 14:20
Date Received: 11/10/2020 11:09
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	11/14/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/14/2020		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/14/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	11/14/2020	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	11/14/2020	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/14/2020	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/14/2020	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	11/14/2020	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/14/2020	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/14/2020		EPA 537.1	2058-94-8

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Sample ID: LJ32711

Work Order: 01101072_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Lenawee County Health Dept.
1040 S. Winter St #2328
Adrian, MI 49221-3871
517 264-5202**

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane