

Official Laboratory Report

Report To: VILLAGE OF BLISSFIELD
1330 BEAMER
BLISSFIELD MI 49228

Sample ID: **LJ66503**
Work Order: **10701386_01**

System Name/Owner: VILLAGE OF BLISSFIELD
Collection Address: 1330 BEAMER, BLISSFIELD
Collected By: NORA KEIFER
Township/Well#/Section: //
County: Lenawee
Sample Point: PLANT TAP
Water System: Treated Public Distribution System

WSSN/Pool ID:
Source: TYPE I
Site Code: TP001
Collector: Other
Date Collected: 07/13/2021 13:12
Date Received: 07/14/2021 11:54
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	07/15/2021		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	07/15/2021		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	07/15/2021	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	07/15/2021	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	07/15/2021	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	07/15/2021	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	07/15/2021	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	07/15/2021	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	07/15/2021	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	07/15/2021		EPA 537.1	2058-94-8

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane