

Official Laboratory Report

Report To: NORA KIEFER
1330 BEAMER RD
BLISSFIELD MI 49228

Sample ID: LK69527
Work Order: 30502711_01

System Name/Owner:	VILLAGE OF BLISSFIELD	WSSN/Pool ID:	0750
Collection Address:	1330 BEAMER RD, BLISSFIELD	Source:	TYPE I
Collected By:	NORA KIEFER	Site Code:	TP001
Township/Well#/Section:	//	Collector:	Other
County:	Lenawee	Date Collected:	05/30/2023 11:30
Sample Point:	PLANT TAP	Date Received:	05/31/2023 10:58
Water System:	Treated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	06/01/2023		EPA 533	763051-92-9
4:2FTS	Not Detected	ng/L	2	06/01/2023		EPA 533	757124-72-4
6:2FTS	Not Detected	ng/L	2	06/01/2023		EPA 533	27619-97-2
8:2FTS	Not Detected	ng/L	2	06/01/2023		EPA 533	39108-34-4
9CI-PF3ONS	Not Detected	ng/L	2	06/01/2023		EPA 533	756426-58-1
ADONA	Not Detected	ng/L	2	06/01/2023		EPA 533	919005-14-4
HFPO-DA	Not Detected	ng/L	2	06/01/2023	370	EPA 533	13252-13-6
NFDHA	Not Detected	ng/L	2	06/01/2023		EPA 533	151772-58-6
PFBA	3	ng/L	2	06/01/2023		EPA 533	375-22-4
PFBS	Not Detected	ng/L	2	06/01/2023	420	EPA 533	375-73-5
PFDA	Not Detected	ng/L	2	06/01/2023		EPA 533	335-76-2
PFDoA	Not Detected	ng/L	2	06/01/2023		EPA 533	307-55-1
PFEESA	Not Detected	ng/L	2	06/01/2023		EPA 533	113507-82-7
PFHpA	Not Detected	ng/L	2	06/01/2023		EPA 533	375-85-9
PFHpS	Not Detected	ng/L	2	06/01/2023		EPA 533	375-92-8
PFHxA	Not Detected	ng/L	2	06/01/2023	400000	EPA 533	307-24-4
PFHxS	Not Detected	ng/L	2	06/01/2023	51	EPA 533	355-46-4
PFMBA	Not Detected	ng/L	2	06/01/2023		EPA 533	863090-89-5
PFMPA	Not Detected	ng/L	2	06/01/2023		EPA 533	377-73-1
PFNA	Not Detected	ng/L	2	06/01/2023	6	EPA 533	375-95-1
PFOA	Not Detected	ng/L	2	06/01/2023	8	EPA 533	335-67-1
PFOS	Not Detected	ng/L	2	06/01/2023	16	EPA 533	1763-23-1
PFPeA	Not Detected	ng/L	2	06/01/2023		EPA 533	2706-90-3
PFPeS	Not Detected	ng/L	2	06/01/2023		EPA 533	2706-91-4

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample ID: LK69527

Work Order: 30502711_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Per-And Polyfluorinated Alkyl Substances							
PFUnA	Not Detected	ng/L	2	06/01/2023		EPA 533	2058-94-8

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Lenawee County Health Dept.
1040 S. Winter St #2328
Adrian, MI 49221-3871
517 264-5202

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane